

- SUF I METAL PIPE FLASHING: SHEET LEAD: MINIMUM OF 2 1/2 LB. PER SQUARE FOOT [12 kg/m<sup>2</sup>] OR SHEET COPPER: MINIMUM 16 OZ. [5 kg/m<sup>2</sup>]. IF USING COPPER FLASHING OVER AN IRON OR STEEL PIPE, INSERT A SEPARATOR SHEET (E.G., ASPHALT-SATURATED ROOFING FELT), WRAPPED AROUND PIPE, TO SEPARATE THE COPPER FLASHING FROM DIRECT 2.
- CONTACT WITH PIPE, TO REDUCE GALVANIC ACTION. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES [305mm] OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. (SEE TABLE 4.) 3.

**PLUMBING STACK** 

ADUREL **POLYMAR ROOFING SYSTEMS** 

APS-1